Note: not to scale

Proposed BPA 500-kV Line Voltage: 540 kV (average), 550 kV (maximum) Peak Current: 1445 (proposed) Conductors: 3 x 1.300 in., 17.04 in. spacing




Figure 2-5 Configurations for the Proposed Wallula-McNary 500-kV Line Proposed line with no parallel lines (Configuration 1) (1 of 5)Wallula Power Project